

Items Discharged to Grease Control Equipment (GCE)

Grease Interceptor – External GCE

- 3 Compartment Sink
- Kitchen floor drains¹
- Mop sink
- Pre-rinse sink²
- Hand sink (will be reviewed if in kitchen area)
- Dishwasher³ – only if pre-rinse cannot be separated from dishwasher. If pre-rinse sink separation is possible, Metro Water Services **does not** want the dishwasher connected to the GCE.

Floor Trap – In-Floor GCE

- 3 Compartment Sink
- Kitchen floor drains¹
- Mop sink
- Pre-rinse sink²
- Dishwasher³ – only if pre-rinse cannot be separated from dishwasher. A separate floor trap unit for the dishwasher may be required for loading, retention, and temperature issues.

Grease Trap – Under sink GCE

- 3 Compartment Sink
- Mop sink
- Pre-rinse sink²
- Dishwasher³ – only if pre-rinse cannot be separated from dishwasher. This should be a separate grease trap unit connected only to the dishwasher.

¹ – only floor drains in the food prep areas are considered. Hub drains, condensate lines, ice machine drain lines, etc. may be exempted from connection to GCE upon GCE Inquiry review.

² – dishwasher pre-rinse discharge

³ – the Department prefers to exclude the dishwasher if we can segregate the dishwasher discharge from the pre-rinse discharge. Failure to exclude the dishwasher will result in requiring larger GCE to help retention time, temperature buffering, and dilution of the emulsifiers/chemicals.